



Vacaville Fire Department Prevention Bureau
650 Merchant St., Vacaville, CA 95688 (707) 449-5453

fire@cityofvacaville.com * www.cityofvacaville.com

IMPORTANT NOTICE REGARDING SMOKE DETECTOR PROVISION AND MAINTENANCE IN HOTELS AND MOTELS

The Vacaville Fire Department would like to inform you about our local smoke detector provision and maintenance requirements for hotels and motels. It is a proven fact that smoke detectors save lives! It is your responsibility as owner/manager to ensure that all smoke detectors are operable at all times. The following suggestions may assist you in monitoring your smoke detector maintenance and help ensure that your smoke detectors are operable at all times. Further, when the Vacaville Fire Department conducts your annual fire inspection we will be looking for the following items:

- The manager/owner should maintain a smoke detector check log. Every time you replace a battery, test a smoke detector or provide any type of maintenance, keep track of this in a log.
- Inspect the smoke detectors a minimum of once every three months and replace the batteries at least annually and when otherwise needed. Keep track of this in the log.
- While the Vacaville Fire Department is performing an inspection of your hotel/motel, we may inspect several smoke detectors. Should we find multiple smoke detectors not functioning properly, we will ask you to maintain more specific records in the future and provide us copies of those records.

The requirement that all smoke detectors remain operable at all times is the responsibility of all owners/managers. A violation of this requirement may subject you to a citation and /or fine in accordance with Section 907 of the 2010 California Fire Code and Vacaville Municipal Code Chapter 14.20.270.

If you have any questions, please call the Vacaville Fire Prevention Bureau at 449-5452.

Owner/Manager: _____ Date: _____
INITIAL AND PRINT NAME